



CENTRE FOR TESTING AND CERTIFICATION - MECH-TEST

Mechanical Laboratory

05-077 Warszawa-Wesoła, ul. Klonowa 22
tel.: +48 603 23-26-45, e-mail: cbc.mech.test@gmail.com, www.cbc.org.pl

Date 17.11.2014


TEST REPORT NO. **CBC-084/2014**

Page 1 of 6

Subject of testing:	<i>Manually propelled wheelchair</i>	Classification according to PN-EN ISO 9999:2011 : 12 21 06
Type / Model:	<i>DOLPHIN</i>	Art.-Nr.: --
Manufacturer:	<i>MOBILEX A/S, Grønlandsvej 5 DK - 8660 Skanderborg</i>	Number of specimens: 1
Applicant:	<i>A-Net s.c. 93-469 Łódź, ul. Łaskowice 174</i>	
Kind of testing	<i>Testing scope according to application of Client Mechanical testing for conformity with PN-EN 12183 : 2011 cl. 7.5,1 ISO 7176 -3:2003; PN - ISO 7176 -8:2002</i>	
Test started:	<i>1. 10. 2014</i>	
Test finished:	<i>17. 11. 2014</i>	

Approved by:

DYREKTOR


mgr inż. Andrzej Tkaczyk

Special comments / enclosures:

Annex 1,2: Identyfikacja of wheelchair elements

Copyright © 2012 by Centre for Testing and Certification (applicable to report form)

Test results refer only to tested units.

Test results reported here are not applicable to the further modifications of the product affecting its structure, material or technology.

This test report shall be neither copied differently as in the whole nor be published without written consent of the Laboratory.



CHARACTERISTIC OF MANUALLY PROPELLED WHEELCHAIR

Name of wheelchair: *Wheelchair*Type/Model: *Dolphin*

Art.-Nr.: --

Maximum load capacity: *200kg*Overall mass of wheelchair: *22,64kg*

Description

Comments

		Description	Comments
Dimensions:	Length:	1043 mm	
	Height:	995-1086 mm	
	Width :	772 mm	
Construction of frame:	Material:	Steel, aluminum	
	Method of fastening frame elements:	Welding, Bolts, nuts	
	Folding/unfolding:	Folding	
Castor wheels	Ø of wheel:	198 mm	
	Width:	44 mm	
	Material of ring of a wheel:	Plastic	
	Material of fork:	Aluminum	
	Vertical adjustment (number of fixing positions)	YES 4	
	Horizontal adjustment (number of fixing positions):	NO	
	Adjustment of axis inclination angle:	YES	
Drive wheels	Ø external:	557 mm	
	Ø pipe:	The cross-section profile in the shape of an ellipse	
	Material:	Aluminum	
	Way of fastening to driven wheel:	--	
	Number of fastening points to driven wheel:	--	
Driving wheels	Material of ring of a wheel:	Aluminum	
	Dimension of tyre:	37-540/24x1 1/2	
	Pressure:	Solid tyre	
	Way of fastening wheel to construction:	Quick connector	
	Vertical adjustment (number of fixing positions)	YES 6	
	Horizontal adjustment (number of fixing positions):	YES 3	
	Inclination angle adjustment:	NO	
	Inclination angle:	0°	
Backrest	Folding/unfolding:	Unfolding	
	Backrest inclination adjustment	stepless:	NO
		number of fixing positions:	--
Tilt levers	Two singular:	YES	
	One lateral:	NO	
Push handles	Kind:	Two separate	
Parking brake	Back:	YES	2 units
	Front:	NO	
	Operated by the occupant:	YES	
	Operated by assistant:	NO	
	Kind:	Lever	
	Material of lever:	Steel	
	Fastening to frame:	With screws and clamp stabilizing position of break towards tyre	
Brake chassis	Kind:	NO	
Upholstery	Material:	Nylon	
	Colour:	Black	

Wheel space in forward direction position:		345 mm	
Wheel space in backward direction position:		453 mm	
Legrests	Common for both legs:	NO	
	Separate for each leg:	YES	
	Stationary:	NO	
	Folding:	YES	
	Vertical adjustment (number of fixing positions)	YES stepless	
	Horizontal adjustment (number of fixing positions):	NO	
	Angle adjustment (number of fixing positions):	NO	
	Material of legrest:	Steel, Aluminum plastic	
Accessories	Seat belt	NO	
	Anti-overturn device:	NO	
	Anterior pelvic support:	YES	
	Service :	NO	

NOTE 1: Measurements were carried out at loading wheelchair with RLG dummy
(angle of backrest – 9,5°, angle of seat plane - 5,5°)

NOTE 2: Footrest was set up in position of 50 mm above base

PHOTO OF WHEELCHAIR



TESTING

NORMATIVE REFERENCES		Applied
PN-EN 12182:2012	Technical aids for disabled persons – General requirements and test methods	NO
PN-EN 12183:2011	Manually propelled wheelchairs – Requirements and test methods	YES
PN-EN 12184:2010	Electrically powered wheelchairs, scooters and their chargers – Requirements and test method	NO
ISO 7176-1:1999	Wheelchairs – Determination of static stability	NO
ISO 7176-2:2001	Wheelchairs – Determination of dynamic stability of electric wheelchairs	NO
ISO 7176-3:2003	Wheelchairs – Determination of efficiency of brakes	YES
ISO 7176-4:2008	Wheelchairs – Energy consumption of electric wheelchairs and scooters and determination of theoretical distance	NO
ISO 7176-5:2008	Wheelchairs – Determination of overall dimensions, mass and turning space	NO
ISO 7176-6:2001	Wheelchairs – Determination of maximum speed, acceleration and retardation of electric wheelchairs	NO
PN-ISO 7176-7:2001	Wheelchairs – Measurement of seating and wheel dimensions	NO
PN-ISO 7176-8:2002	Wheelchairs – Requirements and test methods for static, impact and fatigue strengths	YES
ISO 7176-9:2001	Wheelchairs – Climatic test for electric wheelchairs	NO
ISO 7176-10:2008	Wheelchairs – Determination of obstacle-climbing ability of electric wheelchairs	NO
PN-ISO 7176-14:2001	Wheelchairs – Power and control systems for electric wheelchairs – Requirements and test methods	NO
PN-ISO 7176-15: 2002	Wheelchairs – Requirements for informative disclosure, documentation and labelling	NO
PN-EN 1021-1:2007	Furniture. Assessment of ignitability of upholstered furniture. Ignition source: smouldering cigarette.	NO
PN-ISO 7176-16:2001 equivalent: PN-90/P-04823	Wheelchairs. Resistance to ignition of upholstered parts – Requirements and test methods	NO
PN-ISO 7176-19:2007	Wheelchairs. Wheeled mobility devices for use in motor vehicles	NO
PN-ISO 7193: 2001	Wheelchairs. Maximum dimensions.	NO

Note: Wheelchair with adjustment elements regulated in a factory was performed

TEST RESULTS according to PN-EN 12183:2011

DESIGN REQUIREMENTS

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
7.4.1	V/I	Braking system			
	Measur. 7.4.2.2	Accessibility and possibility to be operated Engaging and disengaging force	-- Conf. 50N/28N	N/T Pos.	requirements on force – see table 1
7.5.3	V/I	No components that protrude above the level of the unoccupied seat when brake is engaged in the wheelchair fitted with movable? or removable arm supports	--	N/T	
		Presence of the system enabling to stop the wheelchair/parking brake	--	N/T	drive wheel operated by the occupant allow to stop the wheelchair
		Possibility to adjust brake	--	N/T	
7.4.2.1 7.4.2.2 7.5.2.2 PN-ISO 7176-3 clause 7	Effectiveness of parking brake (after fatigue test – 60 000 cycles)	Effectiveness of parking brake	Conf. 50N/28N	Pos.	requirements on force applied to brakes – specified in table 1
		- force applied to hand-brakes:	--	N/A	
		- force applied to pushed foot brakes - force applied to pulled foot brakes	-- --	N/A N/A	
		- effectiveness of braking of the wheelchair facing uphill	Conf.	Pos.	no rotation or slide of wheels when the wheelchair is located on inclined plane of 7°
		- effectiveness of braking of the wheelchair facing downhill	Conf.	Pos.	
V/I		Possibility of adjustment and/or replacement of brake	--	N/T	

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
7.4.1	V/I Measur.	Location of brake operation mechanism in the region of access by the occupants (Fig. 2)	--	N/T	If the wheelchair is intended to be operated and driven only by the occupants
		Location of brake operation mechanism in the region of access by an assistant (Fig. 3)	--	N/T	If the wheelchair is intended to be operated and driven only by an assistant
	V/I Measur. ISO 7176-8 7.5.2.1	No deformation, free play or loss of adjustment that adversely affects the function of the wheelchair	Conf.	Pos.	60 000 cycles
7.5.1	V/I 7.5.2.1	Fatigue strength of parking brake	Conf.	Pos.	60 000 cycles $f \leq 0,5$ Hz
7.6.1	7.6.2 7.4.2.2	Operating forces	--	N/T	requirements on forces – in table 1, moments- in clause 7.6.1

TEST RESULTS according to ISO 7176-3:2003

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments	
PN-EN 12183 cl. 7.2.1	7.2 V/I Measur.	Parking brake	Effectiveness of parking brake of wheelchair positioned forwards down the slope	11,0° Conf. Wheelchair slides down	Pos.	No rotation or wheel spin when wheelchair is on inclined plane of 7° slope (requirements of PN-EN 12183 cl. 7.2.1)
			Effectiveness of parking brake of wheelchair positioned backwards down the slope	10,5° Conf. Wheelchair loses stability	Pos.	
			Measurement of force acting on brake lever	Conf. 50N/28N	Pos.	
EN 12184 cl. 8.4	7.3	The effectiveness of the service/automatic brake during drive forwards on horizontal plane and downhill at speeds according to PN- EN 12184:2010 (Table 2)	--	N/A		
EN 12184 cl. 8.4	7.2	Effectiveness of parking brake of wheelchair positioned backwards down the slope	--	N/A		
EN 12184 cl. 8.4	7.2	Effectiveness of parking brake of wheelchair positioned forwards down the slope	--	N/A		
EN 12184 cl. 8.4	7.2	Effectiveness of parking brake of wheelchair positioned backwards down the slope	--	N/A		
EN 12184 cl. 8.4	7.2	Effectiveness of parking brake of wheelchair positioned forwards down the slope	--	N/A		
EN 12184 cl. 8.4	7.3 Annex B	Effectiveness of service/automatic brake during drive forwards on horizontal plane (speed – 6 km/h)	--	N/A		
EN 12184 cl. 8.4	7.5	Effectiveness of emergency brake of wheelchair positioned backwards down the slope	--	N/A		
EN 12184 cl. 8.4	7.5	Effectiveness of emergency brake of wheelchair positioned forwards down the slope	--	N/A		
EN 12184 cl. 8.4	7.7	Effectiveness of emergency brake – during drive forwards on horizontal plane	--	N/A		
EN 12184 cl. 8.4	7.4	Braking distance during drive backwards on horizontal plane	--	N/A		

TEST RESULTS according to PN-ISO 7176-8

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
4.	8.4.	Armrest – resistance to forces acting downwards	Conf.	Pos.	loading 1520 N
4.	8.5.	Footrests - resistance to forces acting upwards	Conf.	Pos.	loading 150kg, NOTE 1
4.	8.6.	Anti-tip levers	Conf.	Pos.	loading 200kg
4.	8.7.	Grips	1500 N	Pos.	taking off force ≥ 750 N with user weight 100kg NOTE 2
4.	8.8.	Armrest – forces acting upwards	Conf.	Pos.	
4.	8.9.	Footrest – forces acting upwards	Conf.	Pos.	NOTE 4
4.	8.10.	Handle grips for pushing – load acting upwards	Conf.	Pos.	NOTE 5
4.	9.3.	Backrest – impact strength	Conf.	Pos.	25kg pendulum impact
4.	9.4.	Driving wheel – impact strength	Conf.	Pos.	10kg pendulum impact

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
4.	9.5.	Castor/front wheel – impact strength	Conf.	Pos.	10kg pendulum impact
4.	9.6.3.	Footrest – side impact	Conf.	Pos.	10kg pendulum impact
4.	9.6.4.	Footrest – in-line impact	Conf.	Pos.	10kg pendulum impact
4.	9.7.2.	Frontal part of wheelchair – directly impact	Conf.	Pos.	10kg pendulum impact
4.	9.7.3.	Frontal part of wheelchair – displaced impact	Conf.	Pos.	10kg pendulum impact
4.	10.4.2.	Testing of manually propelled wheelchair on two-drum machine	Conf.	Pos.	200 000 of cycles with full loading of wheelchair (200kg)
4.	10.4.3.	Measurement of initial current for electrically powered wheelchair	--	N/A	
4.	10.4.4.	Testing of electrically powered wheelchair on two-drum machine	--	N/A	
4.	10.5.	Drop testing	Conf.	Pos.	6666 drops of wheelchair with full loading 200kg from height of 50mm

Pos. – positive; Neg – negative; N/T – not tested; N/A – not applicable; N/R – not required, N/O – not occurred, V/I. - visual inspection, Conf.- conformed.

NOTE 1: PN-EN 12183:2011 cl.1 and PN-ISO 7176-8 cl.1 specify requirements and test methods for manual wheelchairs intended to carry one person of mass not greater than 100kg.

The footrest loaded with a mass of 100kg - a positive test result.

The footrest loaded with a mass of 150kg - a positive test result.

NOTE 2: The handle can withstand loads of 750N. The handle begins to slip under load 1500N.

NOTE 4: The construction of the footrests stand the test of the rising up of the wheelchair with the user (200kg) (Annex B-2).

NOTE 5: The test to raise up the wheelchair with the user (200kg), using handles for pushing, successfully passed.

NOTE 7: During visual inspection before testing any visible defects that can have an effect on test results were not stated.

NOTE 8: Tests were carried out on the wheelchair with adjustment elements set according to recommendations of the manufacturer and according to requirements of PN-ISO 7176-22:2006.

NOTE 9: Sample/object for testing was delivered to the Laboratory by the Orderer.

NOTE 10: Test dummy of mass 200 kg were used for testing.

NOTE 11: Environment temperature for testing - 18°C.










Final assessment			
PN-EN 12182:2012	N/T	PN-ISO 7176-7:2001	N/T
PN-EN 12183:2011	Pos.	PN-ISO 7176-8:2002	Pos.
PN-EN 12184:2010	N/A	ISO 7176-9:2001	N/A
ISO 7176-1:1999	N/T	ISO 7176-10:2008	N/A
ISO 7176-2:2001	N/A	PN-ISO 7176-14:2001	N/A
ISO 7176-3:2003	Pos.	PN-ISO 7176-15: 2002	N/T
ISO 7176-4:2008	N/A	PN-ISO 7176-16:2001	N/T
ISO 7176-5:2008	N/T	PN-EN 1021-1:2007	N/T
ISO 7176-6:2001	N/A	PN-ISO 7176-19:2007	N/T
		PN-ISO 7193:2001	N/T

Note: Conformity assessment of product according to standard requirements refer to the scope of mechanical tests ordered by client, excluding testing of material biocompatibility with human body according to PN-EN ISO 10993-1:2010

- END -

ANNEX 1 TO TEST REPORT No. CBC 084/2014

Identification of product elements



ANNEX 2 TO TEST REPORT No. CBC 084/2014

Identification of product elements

