



CENTRE FOR TESTING AND CERTIFICATION - MECH-TEST
Mechanical Laboratory

05-077 Warszawa-Wesoła, ul. Klonowa 22
tel.: +48 603 23-26-45, e-mail: cbc.mech.test@gmail.com, www.cbc.org.pl

Date 25.02.2014

TEST REPORT NO. CBC-027/2014

Page 1 of 6

Subject of testing:	<i>Shower chair</i>	Classification according to PN-EN ISO 9999:2011:	09 12 03
Type / Model:	<i>Kakadu XL</i>	SN.:	<i>302020</i>
Manufacturer:	<i>MOBILEX A/S Grønlandsvej 5, DK-8660 Skanderborg</i>	Number of specimens:	<i>1</i>
Applicant:	<i>A-Net s.c., ul. Łaskowice 174, 93-469 Łódź</i>		
Kind of testing	<i>Testing scope according to application of Client Mechanical testing for conformity with PN-EN 12182:2012</i>		
Test started:	<i>27.01.2014</i>		
Test finished:	<i>25.02.2014</i>		

Approved by:

DYREKTOR

mgr inż. Andrzej Tkaczyk

Special comments / enclosures:

1) Annex 1 – Identification of product elements

Copyright © 2012 by Centre for Testing and Certification (applicable to report form)

Test results refer only to tested units.

Test results reported here are not applicable to the further modifications of the product affecting its structure, material or technology.

This test report shall be neither copied differently as in the whole nor be published without written consent of the Laboratory.



TECHNICAL DATA

Name : SHOWER CHAIR - KAKADU XL		SN: 302020	
Maximum permissible user mass:	200 kg	Mass of product:	14,1 kg
Length with footrest:	900mm	Height:	968/993/1018mm
Length without the footrest:	628mm	Length of seat:	425mm
Width:	664mm	Seat height above the ground:	495/520/545mm
Width of seat:	565mm	Clearance:	398/423/448mm
Diameter of the wheels:	124mm	Distance between armrests:	620mm
Width of the wheels:	31mm	Length of armrests:	240mm
Force of the parking brake switch	75N	Height of armrests:	200mm
Release the parking brake force:	35N	Force the release hook footrest:	25N
		Brakes:	4 x footbrake

PHOTO OF PRODUCT



MOBILEX A/S
Grønlandsvej 5
DK-8660 Skanderborg
Tel: +45 87 93 22 20
www.mobilex.dk

Shower chair



Max. 200 kg



Produced

Serial no.

TESTING

NORMATIVE REFERENCES

Applied

PN-EN 12182:2012	Technical aids for disabled persons – General requirements and test methods	YES
PN-EN 12183:2011	Manually propelled wheelchairs – Requirements and test methods	YES
ISO 7176-1:1999	Wheelchairs – Determination of static stability	YES
ISO 7176-3:2003	Wheelchairs – Determination of efficiency of brakes	YES
PN-ISO 7176-8:2002	Wheelchairs – Requirements and test methods for static, impact and fatigue strengths	YES
PN-EN 1021-1:2007	Furniture. Assessment of ignitability o upholstered furniture. Ignition source: smouldering cigarette.	YES
PN-EN 71-1:2011	Safety of toys. Mechanical and physical properties	YES

TEST RESULTS according to PN-EN 12182 : 2012

Requirement s according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments	
4.1	4.8, 5.2, 5.4.2, 5.5, 6, 8.2.1, 9.4, 10, 22, 24 i EN 1441	Risk analysis	--	N/T		
4.2	V/I	Expected characteristics and technical documentation	Conf.	Pos.		
4.3	EN ISO 14155	Clinic assessment	--	N/T		
4.4	V/I	Technical support which can be dismantled	--	N/A		
4.5	V/I	Single use connections	--	N/A		
4.6	V/I	Boundary values of user weight	Conf.	Pos.		
4.7	V/I	Immobilising means	Conf.	Pos.		
4.8	V/I, C5	Suitability of the product for people with cognitive impairment	--	N/T		
		The presence of the description in the manufacturer's documentation	--	N/T		
Materials						
5.1	EN 60601-1-9	Recycling	--	N/T		
5.2	V/I, B 5.2	Flammability (PN-EN 1021-1:2007)	Conf.	Pos.	NOTE 10	
5.2.2	V/I	Upholstered parts, mattresses, bed bases and bedding	--	N/A		
5.2.3	V/I, EN 1021	Upholstered parts	--	N/A		
5.2.4	V/I, EN 597	Mattresses and bed bases	--	N/A		
5.2.5	V/I, EN ISO 12952	Bedding	--	N/A		
5.2.6	V/I, EN 60695-11-10	Moulded parts	--	N/T		
5.3	EN ISO 10993-1 Annex. D	Biological conformity and toxicity	--	N/T		
5.4	V/I	Contaminants and residues	--	N/A		
5.5	V/I, B.5.5.1	Microbiological infections and contamination	Cleaning	Conf.	Pos.	Comments in service manual
	V/I, B.5.5.1		Disinfection	--	N/A	
	V/I, EN ISO 22442-1 B.5.5.2		Animal tissue	--	N/A	
5.6	EN ISO 9227	Resistance to corrosion	--	N/T		
6		Emitted sound and vibration				
6.1	EN ISO 3746 B6	Noise and vibration	--	N/A		
6.2	EN ISO 3746	Sound levels and frequencies of audible warning devices	--	N/A		
6.3	EN ISO 3746	Feedback	--	N/A		

Requirement s according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
7	EN 60601-1-2 7.2, 7.3, 7.4	Electromagnetic compatibility	--	N/A	
8		Electrical safety	--	N/A	
9	V/I	Overflow, spillage, leakage, and ingress of liquids	--	N/A	
10	V/I. Measur.	Surface temperature	--	N/A	$t^{\circ} \leq 41^{\circ}C$ ■ requirement does not concern heat of direct solar radiation - PN- EN 12182, clause 10a ■ requirement concerns only persons with insensitiveness of skin (who do not feel heat) - PN-EN 12182, clause 10d
11	V/I	Sterility	--	N/A	
12	V/I. Measur.	Safety of moving parts	Conf.	Pos.	
13	V/I. Measur.	Prevention of traps for parts of the human body	Conf.	Pos.	
14	V/I	Folding and adjusting mechanisms	Conf.	Pos.	
15	V/I. Measur.	Carrying handles	--	N/A	
16	V/I. Measur.	Assistive products which support or suspend users	Conf.	Pos.	NOTE 6
17	V/I. Measur.	Portable and mobile assistive products	Conf.	Pos.	NOTE 7
18	V/I, B 18	Surfaces, corners, edges and protruding parts	Conf.	Pos.	
19	B 19	Hand held assistive products	--	N/A	
20	B 20	Small Parts	Conf.	Pos.	NOTE 8
21	V/I. Measur. EN 60601-1	Stability	Conf.	Pos.	NOTE 9
22	B 22, V/I	Forces in soft tissues of the human body	Conf.	Pos.	
23	V/I. EN 614-1	Ergonomic principles	--	N/T	The requirements relate to the design process
24	V/I	Requirements for information supplied by the manufacturer			
24.1		General	--	N/T	
24.2		Instructions for use	--	N/T	
24.2.1	V/I	Pre-sale Information			
		a) information on how to obtain the user information in a format appropriate for use by people with visual, reading or cognitive disabilities	--	N/T	
		b) all information shall as far as possible be available in Pictogram	--	N/T	
		c) a description of the intended use and the intended environment;	--	N/T	
		d) maintenance instructions, if applicable;	--	N/T	
		e) if an assistive product is intended to be cleaned, a description of the method and suitable cleaning materials, including precautions needed to avoid corrosion, if applicable;	--	N/T	
		f) if an assistive product is intended to be disinfected, a description of the method and suitable materials, including any precautions needed to avoid corrosion, if applicable;	--	N/T	
		g) the overall dimensions (width, length and height) of the assistive product, expressed in millimetres, and its mass, expressed in kilograms, when it is ready for use and, if applicable, when it is folded or dismantled	--	N/T	
		h) the mass expressed in kilograms if the assistive product can be dismantled or has any removable parts that has a mass which is heavier than 10 kg;	--	N/T	
		i) if the assistive product is supposed to be used in combination with other products, the manufacturer shall state to which products, and how this can be done in a safe way;	--	N/T	
		j) warning about dangerous combinations of devices (e.g. cushions for the prevention of decubitus ulcers often only work on correct seat surface) and combinations of flame resistant and non-flame resistant material;	--	N/T	
		k) a list of accessories, detachable parts and materials that the manufacturer has determined as being intended for use with the assistive product	--	N/T	

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
24.2.1	V/I	l) if a programmable controller is fitted, information on the method of programming, the competence required to carry out the programming and the effects on performance	--	N/T	
		m) operator control adjustments	--	N/T	
		n) whether and how the assistive product can be folded or dismantled to assist in storage or transport	--	N/T	
		o) instructions regarding transport of the assistive product (e.g. in a car or aeroplane)	--	N/T	
		p) measured sound power level	--	N/T	
24.2.2	V/I	User information			
		User information shall be provided by the manufacturer with each assistive product. Information shall contain all pre-sale warnings and informations and the following as applicable for each assistive product:	--	N/T	
		a) the location and the type of identification number/word on the assistive product shall be given for the unique identification number of the assistive product	--	N/T	
		b) the intended user	--	N/T	
		c) any adjustment or settings required before the assistive product can be used and information on how adjustments or settings affect the assistive product	--	N/T	
		d) information on adjustment possibilities and the competence required to carry out these adjustments	--	N/T	
		e) instructions on operation of all controls	--	N/T	
		f) the battery type and nominal voltage	--	N/T	
		g) instructions for battery maintenance	--	N/T	
		h) instructions for operating the battery charger, including warnings regarding any potential safety hazards (e.g. a possibility of gas accumulating in the charging area);	--	N/T	
24.2.2	V/I	i) instructions on dismantling and re-assembly of the assistive product or any removable parts;	--	N/T	
		j) the positions of points where the component parts can be gripped for safe moving and handling and/or a method for handling during dismantling, assembly or carrying;	--	N/T	
		k) a warning if surface temperatures can increase / decrease when exposed to external sources of heat or cold (e.g. sunlight, outdoor environment);	--	N/T	
		l) a warning if the assistive product might disturb the operation of devices in its environment that emit electromagnetic fields (e.g. alarm systems of shops, automatic doors, etc.);	--	N/T	
		m) a warning if the performance of the assistive product can be influenced by electromagnetic fields {e.g. those emitted by portable telephones, electricity generators or high power sources);	--	N/T	
		n) if the intended purpose of an assistive product cannot be met without a hazard {e.g. holes, V-shaped opening), a warning and instructions on how to operate the assistive product safely;	--	N/T	
		o) if the intended purpose of an assistive product cannot be met without a hazard due to moving parts such as squeezing, a warning and instructions on how to operate the assistive product safely;	--	N/T	
		p) the level of resistance to ignition of materials and assemblies;	--	N/T	
24.2.2	V/I	q) information on the recycling of used batteries and other parts of the assistive product;	--	N/T	
		r) expected lifetime of the assistive product.	--	N/T	
		- It is recommended to include instructions on how to solve simple problems for the ease of use.	--	N/T	
24.2.3	V/I	Service information			
		The service information shall contain all the pre-sale information, user information and instructions necessary for the maintenance, adjustment and repair of the assistive product and for the replacement of parts.	--	N/T	
		The service information shall contain all the pre-sale information and the user information.	--	N/T	
		The service information shall be sufficiently detailed concerning preventive inspection, maintenance and calibration, including the frequency of such maintenance.	--	N/T	

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
		The service information shall provide information for the safe performance of such routine maintenance necessary to ensure the continued safe use of the assistive product.	--	N/T	
		Additionally, the service information shall identify the parts on which preventive inspection and maintenance shall be performed by service personnel, including the periods to be applied and details about the actual performance of such maintenance.	--	N/T	
24.3	V/I	Labelling			
		- year of production for the product	--	N/T	
		- Detachable parts of an assistive product with a mass of more than 10 kilograms shall be marked with the actual mass on the part.	--	N/T	
		- Symbols for use in the labelling of medical devices shall be in accordance with EN 980	--	N/T	
25	V/I	Packaging	--	N/T	

Pos. – positive; Neg – negative; N/T – not tested; N/A – not applicable; N/R – not required, N/O – not occurred, V/I – visual inspection, Conf. – conformed.

NOTE 1: Service manual not evaluated

NOTE 2: During visual inspection before testing any visible defects that can have an effect on test results were not stated.

NOTE 3: Sample/object for testing was delivered to the Laboratory by the Orderer.

NOTE 4: Test dummy of mass 200 kg were used for testing.

NOTE 5: Environment temperature for testing - 19°C, humidity of air 60%.

NOTE 6: ● Wheelchair was loaded with a static load of 1,5 times the mass of the user (300kg) for a period of time 70 seconds. A positive test result.

● The test was conducted of the product loaded with the mass of the user on fatigue two-drum test stand (obstacles disassembled) according to ISO 7176-8:2002, clause 10.4.2. After 200 000 cycles, the product worked in accordance with the manufacturer's information.

● A fatigue test of brakes was conducted according to EN 12183:2011, section 7.5.2.1.

After 60 000 cycles, brakes worked in accordance with the manufacturer's information.

● Forces were measured according to EN 12183:2011, Section 7.6.2, 7.4.2.2, (Requirements - Table 1)

Strength releasing the footrest lock - 25 N,

Power on / releasing the parking brake - 75 N / 35 N

● Brakes performance was measured according to ISO 7176-3:2003.

No rotation or wheel spin when product is on inclined plane of 7° slope

(requirements of PN-EN 12183 cl. 7.4.2.1, Tab. 1). A positive test result.

NOTE 7: ● There were made three dumps of the product with a full load of 30mm. A positive test result.

● Three-time raiding of the product with a full load at a speed of 0.4 m / s on the step of height 10mm. The test positive.

Due to the small diameter of the wheels (124mm) and the possibility of entry of the product on the threshold / step having a height of 10mm - use of the product - within the premises of thresholds / steps with a height of less than 10mm.

● Three-time raiding of the product with a full load at a speed of 0.4 m / s from the step of height 40mm. The test positive.

● Three times hitting the vertical wooden barrier by the front of the product with a full load, running at a speed of 0.4 m / s. Positive test result.

NOTE 8: There are not separable small parts in the child access area that could fit without forces in small parts tester. (PN-EN 71-1:2011, cl. 8.2, fig. 18).

NOTE 9: Stability tests were repeated according to ISO 7176-1:1999. Rear stability rear is 16°, lateral stability is 27°. Front stability is 16°.

NOTE 10: There is no ignition of upholstery fabric surface.

CONCLUSIONS:

Testing object **conforming** with requirements of PN-EN 12182:2012

Note: Conformity assessment of product according to standard requirements refer to the scope of mechanical tests ordered by client, excluding testing of material biocompatibility with human body according to PN-EN ISO 10993-1:2010

- END -

ANNEX 1 TO TEST REPORT No. CBC-027/2014

Identification of product elements

