



POLISH CENTRE FOR TESTING AND CERTIFICATION

02-699 Warszawa, ul. Kłobucka 23A

Mechanical Laboratory

tel.: (+48 22) 46 45 594; fax: (+48 22) 46 45 563

e-mail: labmech@pcbc.gov.pl

Date: 22.12.2011

TEST REPORT NO. BR – 256/L-377/2011

Page 1 of 5

Subject of testing: *Alligator Ramps*

Classification according to PN-EN ISO 9999:2007 :
18 30 15

Type / Model: *DF 300*

Catalogue no.: 2011307

Manufacturer : *MOBILEX A/S, Nørskovvej
DK - 8660 Skanderborg*

Number of specimens : 1

Applicant: *A-Net s.c. 93-469 Łódź,
ul. Łaskowice174*

Kind of testing *Testing scope according to application of Client
Mechanical testing for conformity with PN-EN 12182:2005, clause 16*

Test started: 14.12.2011

Test finished : 22.12.2011

Performed by:

Mirosław Szymański

Checked by :

Ireneusz Czerwiński

Approved by :

KIEROWNIK
LABORATORIUM MECHANICZNEGO

mgr inż. Andrzej Tkaczyk

Special comments / enclosures:

Copyright © 2005 by Polish Centre for Testing and Certification (applicable to report form)

Test results refer only to tested units.

Test results reported here are not applicable to the further modifications of the product affecting its structure, material or technology.

This test report shall be neither copied differently as in the whole nor be published without written consent of the Laboratory.








TESTING

NORMATIVE REFERENCES

PN-EN 12182:2005

Technical aids for disabled persons – General requirements and test methods

PHOTO OF PRODUCT



CHARAKTERISTICS OF PRODUCT

Name of product: <i>Alligator Ramps</i>	Max. loading: 300 kg	Mass of product: 28,3 kg 2 x 14,15 kg
Dimensions:		
Height max. :	127 mm	
Width (max.):	790 mm (828 mm)	
Length max. :	3000 mm	
of the ramp to transport:	1550 x 423 x 209 mm	
Material:	aluminum, plastic	

TEST RESULTS according to PN-EN 12182 : 2005

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
4.1	5.2, 5.4.2, 5.5, 6, 8.2.1, 9.4, 10, 22, 24 i EN 1441	Risk analysis	--	N/T	
4.2	V/I	Expected characteristics and technical documentation	--	N/T	
4.3	EN-540	Clinic assessment	--	N/T	
4.4	V/I	Technical support which can be dismantled	--	N/T	
4.5	V/I	Single use connections	--	N/T	
4.6	V/I	Boundary values of user weight	--	N/T	
5.1	V/I	Flammability	--	N/T	
5.2	EN ISO 10993-1	Biological conformity and toxicity	--	N/T	
5.3	V/I	Impurities and residues	--	N/T	
5.4	24, Annex.C C.5.4.1	Microbiological infections and contamination	Cleaning	--	N/T
	24, Annex.C C.5.4.1		Disinfection	--	N/T
	EN 12442-1		Animal tissue	--	N/T
6	Measur.	Noise	--	N/T	
7	Measur.	Electromagnetic compatibility	--	N/T	
8	EN60601-1 EN60335-1	Electrical safety	--	N/T	
9	V/I	Overflowing, pouring out, leakage and pouring in of liquids	--	N/T	
10	V/I. Measur.	Surface temperature	--	N/T	$t' \leq 41^{\circ}C$ ■ requirement does not concern heat of direct solar radiation - PN-EN 12182, clause 10a ■ requirement concerns only persons with insensitiveness of skin (who do not feel heat) - PN-EN 12182, clause 10d
11	V/I	Sterility	--	N/T	
12	V/I. Measur.	Safety of moving elements	--	N/T	
13	V/I. Measur.	Trap prevention for parts of human body	--	N/T	
14	V/I	Folding and adjusting of mechanisms	--	N/T	
15	V/I. Measur.	Hand grips for transferring	--	N/T	
16	V/I. Measur.	Aids for support of users	Conf. elastic deformation 49 mm, sustained deformation 2 mm	Pos.	loading 450 kg in the time 70 sec.
17	V/I	Portable and moving technical aids	--	N/T	
18	V/I	Surfaces, corners and edges	--	N/T	
19	Annex.C,C18	Hand kept technical aids	--	N/T	
20	V/I	Grips and other elements for transferring	--	N/T	
21	V/I	Force action on soft tissues of human body	--	N/T	
22	Annex.C22	Ergonomic principles – action force	--	N/T	The requirements relate to the design process

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Test result	Opinion	Comments
23	V/I	Information provided by manufacturer			
		1) Advice on which other devices and/or types of device can be used in combination with a technical aid an precaution or limitations needed to ensure safety use, i.e.:			
		- Warnings and advice about precautions relating to high and/or low temperature surface (clause 10)	--	N/T	
		- Warnings and advice about precautions relating to safe distances between moving and stationary parts (clause 12, 13)	--	N/T	
		- Instructions on how to fold and/or adjust aids and warnings and advice about precautions needed to avoid hazards (clause 14)	--	N/T	
		- Advise on safe lifting and handling (clause 20)	--	N/T	
		- The level of protection of electrical equipment against the ingress of liquid and advice on the intended environments of use and related safety recommendations (clause 9)	--	N/T	
		- Information on dangerous combination of devices	--	N/T	
		2)- Presence of information intended for use by persons with reading difficulties, in a form that they can comprehend	--	N/T	
		- Presence of information in a tactile (e.g. Braille) or audio form intended for use by persons with visual impairment	--	N/T	
		3) Presence of maintenance and cleaning instructions	--	N/T	
4) Presence of information on maximum mass of disabled person	--	N/T			
5) Presence of information on precautions and safety use if a technical aid is not flame resistant and/or does not comply with flammability requirements (clause 5.1)	--	N/T			
6a) Presence of information on intended environment of use and description of hazards if a technical aid may be affected by electromagnetic emissions	--	N/T			
6b) Presence of information on how to correct any malfunctions	--	N/T			
7) Presence of description of the method and suitable cleaning materials including any precautions needed to avoid corrosion if a technical aid is intended to be cleaned	--	N/T			
8) Presence of description of the method and suitable disinfection materials including any precautions needed to avoid corrosion if a technical aid is intended to be disinfected	--	N/T			
9) Presence of warnings and advice about precautions relating to high output sound levels if a technical aid can create a noise hazard	--	N/A			
24	V/I	Package	--	N/T	Note 2

Pos. – positive; Neg – negative; N/T – not tested; N/A – not applicable, N/O – not occurred ,
V/I.- visual inspection, Conf.- conformed.

NOTE 1. Conformity assessment of product according to standard requirements refer to the scope of mechanical ordered by client

NOTE 2: During visual inspection before testing any visible defects that can have an effect on test results were not stated.

NOTE 3: Sample/object for testing was delivered to the Laboratory by the Orderer.

CONCLUSIONS:

*Testing object **conforming** with requirements of PN-EN 12182 :2005, clause 16*

----END----